



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

October 15, 2003
Subject: Project STP-9720 (00)X
PIN 9720.00
Castine - Penobscot
Bid Amendment No. 2

Dear Sir/Ms.:

Please make the following change to your Bid Package:


In the Construction Notes; Item 310.14 C.I.P., add the following note; "Milled material from Item 202.127 will be used for cross slope correction as directed by the Resident. Payment will considered incidental to Item 310.14."

Q. Are cross sections available for all of the common excavation areas?

A. Cross sections are included in the Bid book for Sta. 2+044 to 2+159 and Sta. 8+074 to 8+144. The three remaining sections; Sta. 2+290 to 2+590, Sta. 3+230 to 3+290, and Sta. 4-971 to 5+029; are base cut sections. The existing material will be removed to a depth of 600 mm.

Consider this change prior to submitting your bid on October 22, 2003.

Sincerely,


for Bruce R. Carter
Contracts Engineer



PRINTED ON RECYCLED PAPER